

DG TYPE EXAMINATION CERTIFICATE

No.
DG-2638

This is to certify that:

Danish Institute of Fire and Security Technology, specified as a "notified body" under the terms of the Danish Safety Technology Authority, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Danish Gas Regulations, Section C-2, subject to any conditions in the description attached hereto.

Applicant Saint-Gobain Distribution Denmark
Address Park Allé 370, DK-2605 Brøndby
Manufacturer Starline SpA
Type of Appliance Ball valve
Trade Mark EGO
Type/Model 125/225/126/226
135/235/136/236
Specified Standards DIN 3537 part 1

**The attached (*description of type approval*) forms part of this certificate.
This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.**

Date of issue 2012-06-28 Issued by Danish Institute of Fire and Security Technology
Notified Body No. **0845**

Signed

Name

Ken Olesen

Note:

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.



Subject to compliance with the conditions in the annex "Description of Type Approval", which forms part of this certificate, and those of the Regulations, the Manufacturer is allowed to affix the "Mark of Conformity" to the product described herein.

xxxx DG approval number

This certificate is issued under the authority of the Danish Safety Technology Authority.

(Annex)
Description of Type Approval

Product Description

Trade Marks EGO
Type/Model 125/225/126/226
135/235/136/236

Technical Data

Category: III
Max. pressure 4 bar
Dimensions: 1/2" – 2"
Materials: Body: stainless steel 316 or carbon steel LF2
Ball: stainless steel 316
Gasket: PTFE

Comments: The valves shall be marked with "DG-2638"

Type Approval Documentation

Test report : DGP test report no 2638/1 dated 1989-04-03 based on the following standard:
- DIN 3537, part 1

Drawings: List of drawings

Approval certificate No. : -

Others: -

End of Certificate