



## DG TYPE EXAMINATION CERTIFICATE

No.  
DG-2368

This is to certify that:

Danish Institute of Fire and Security Technology, specified as a "notified body" under the terms of the Danish Safety Technology Authority, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Danish Gas Regulations, Section C-2, subject to any conditions in the description attached hereto.

**Applicant** Saint-Gobain Distribution Denmark  
**Address** Park Allé 370, DK-2605 Brøndby  
**Manufacturer** JC Fabrica de Valvulas SA  
**Type of Appliance** Ball valve  
**Trade Mark** EGO  
**Type/Model** 516/540 AIT/IIT  
**Specified Standards** DIN 3537 part 1

**The attached (*description of type approval*) forms part of this certificate.  
This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.**

Date of issue 2013-03-12 Issued by Danish Institute of Fire and Security Technology  
Notified Body No. **0845**

Signed

Name

Ken Olesen

Note:

**This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.**



Subject to compliance with the conditions in the annex "Description of Type Approval", which forms part of this certificate, and those of the Regulations, the Manufacturer is allowed to affix the "Mark of Conformity" to the product described herein.

xxxx DG approval number

**This certificate is issued under the authority of the Danish Safety Technology Authority.**



(Annex)  
**Description of Type Approval**

**Product Description**

**Trade Marks** EGO  
**Type/Model** 516/540 AIT/IIT

**Technical Data**

**Category:** III  
**Max. pressure** 16 bar  
**Dimensions:** DN 15 – DN 200  
**Materials:** Body: Cast steel 25 (1.0619) / Stainless steel 316 (1.4408)  
Ball: Stainless steel A 351 Gr. CF8M (DN 15 : 25 A 479 Tp.316)  
Gasket: PTFE

**Comments:** The valves shall be marked with "DG-2368"

**Type Approval Documentation**

**Test report :** DGP test report no 2368/0 dated 1987-01-39 based on the following standard:  
- DIN 3537, part 1

**Drawings:** List of drawings

**Approval certificate No. :** -

**Others:** -

**End of Certificate**